

Spills and Overflows from July 2002 through June 2003

LOCATION	DATE	VOLUME gallons	CAUSE	REMEDIES	IMPACT
Englewood Ave. & Arbor St.	09/10/02	3,000	Broken 8 inch Aerial Main Line	Replaced with 12ft. 6 inches of Ductile Iron Pipe	None noted
1116 Liberty St.	09/27/02	1,000	Blockage of grease/rags	Cleaned and TVed main line	None noted
Oakland Ave. & Wilson St.	11/04/02	1,000	Blockage of grease/roots	Cleaned and TVed main line	None noted
Buchanan Blvd. north of I-85	11/21/02	40,000	Grease blockage	Cleaned and TVed main line	None noted
Cedar Creek Pump Station	12/05/02	700	Power Failure/Back-up Generator failed	Generator fault was reset	None noted
Rivermont Pump Station	12/06/02	50,000	Power Failure/Back-up Generator failed	Generator fault was reset	None noted
Turnage Heights Pump Station	12/09/02	14,000	Power Failure/Back-up Generator failed	Generator replaced	None noted
E.Club Blvd. & Glenbrook Dr.	12/13/02	175,000	City Contractor left plug in line too long	Contractor will leave employee on site while lines are plugged	None noted
106 Goley St.	12/23/02	5,000	Grease blockage	Cleaned and TVed main line	None noted
307 Obie St.	12/30/02	1,500	Blockage of grease/roots	Cleaned and TVed main line	None noted
Liberty St. & Barnes Ave.	01/10/03	17,000	Blockage of grease/sludge	Cleaned and TVed main line	None noted
Heritage Dr. Pump Station	01/14/03	8,400	Level control failure	Bubbler line was repaired	None noted
100 Lakeshore Dr.	01/26/03	13,500	Blockage of grease/rags	Cleaned and TVed main line	None noted
Bynum St. (end) off Anderson St.	02/04/03	3,000	Blockage of roots	Cleaned and TVed main line	None noted
Lambeth Circle (aerial line)	02/23/03	9,000	Large tree fell causing break in 10 inch cast iron main	Replaced with 6 ft. of Ductile Iron main	None noted
Cedar Creek Pump Station	02/27/03	350	Power failure/Pump breakers tripped	Breakers were reset	None noted
Cannon Dr. & Zenith St.	03/26/03	8,600	Blockage of roots	Cleaned and TVed main line	None noted
4600 University Dr.	03/26/03	7,200	Blockage of rags/roots		None noted
Bynum St. (end) off Anderson St.	04/03/03	500	Blockage of grease/roots	Cleaned and TVed main line	None noted
Highgate Dr. & Hurdle Ct.	04/04/03	50,000	Blockage caused by broken manhole lid falling into invert	Cleaned and TVed main line/Grouted main as part of City Contract	None noted
Pettigrew St. between Roxboro St. & Dillard St.	04/23/03	10,000	Contractor damaged 60 ft. of main line while installing cable	Cleaned and TVed main line/City crew replaced 65 ft. of 8 inch sewer main	None noted

<i>Spills and Overflows from July 2002 through June 2003</i>					
LOCATION	DATE	VOLUME gallons	CAUSE	REMEDIES	IMPACT
3000 Sparger Rd.	04/24/03	3,600	Grease blockage	Cleaned and TVed main line	None noted
S.Woodcrest St. (dead-end)	05/12/03	500	Blockage of roots/rags	Cleaned, sawed roots and TVed main line	None noted
S.Roxboro St. & Gaithers Pointe Dr.	05/20/03	5,000	Vandalism (large rock)	Cleaned and TVed main line	None noted
1802 Palmer St.	06/03/03	700	Blockage of grease/roots	Cleaned and TVed main line	None noted
610 Monticello Ave.	06/06/03	12,000	Blockage of roots/rags	Cleaned, sawed roots and TVed main line	None noted
Belvin Ave. beyond cul-de-sac	06/14/03	9,000	Blockage of grease/roots	Cleaned and TVed main line	None noted
Morehead Ave. & Burke St. (Maplewood Cemetery)	06/24/03	6,000	Grease blockage	Cleaned and TVed main line	None noted
Total Spills = 28		445,550	Total Gallons		

Important Phone Numbers

Report leaking/broken sewer lines, clogged sewer lines

Monday – Friday, 7:00 am until 4:00 pm

919-560-4344

After hours, weekends, holiday

919-560-4348

Ask questions about your water/sewer bill

919-560-4411

Questions about sewer taps, applications, extensions

919-560-4326

Report illegal dumping in storm drain

919-560-SWIM (7946)

Questions about wastewater treatment, tours of facilities

919-560-4381

Questions about Household Hazardous Waste collection/disposal

919-287-8051

Other questions about City services? Check out the City's website at www.ci.durham.nc.us